

**SANTA CLARA UNIFIED SCHOOL DISTRICT
LEAD TESTING OF DRINKING WATER RESULTS 2018**

ELEMENTARY SCHOOLS

Bowers Elementary School					
Initial Sample Date: 9/13/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Bracher Elementary School					
Initial Sample Date: 9/13/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	7.3	ND	ND
Resample Date: 10/11/2018	ND		12.0		
Resample Date: 11/8/2018 Corrective Action Taken			10.0		
Resample Date: 12/4/2018 Corrective Action Taken			ND		

Braly Elementary School					
Initial Sample Date: 4/25/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Briarwood Elementary School					
Initial Sample Date: 9/19/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Central Park Elementary School					
Initial Sample Date: 9/20/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Haman Elementary School					
Initial Sample Date: 9/20/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Hughes Elementary School					
Initial Sample Date: 9/26/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

**SANTA CLARA UNIFIED SCHOOL DISTRICT
LEAD TESTING OF DRINKING WATER RESULTS 2018**

ELEMENTARY SCHOOLS

Laurelwood Elementary School					
Initial Sample Date: 9/21/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Mayne Elementary School					
Initial Sample Date: 4/3/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Millikin Elementary School					
Initial Sample Date: 9/21/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Montague Elementary School					
Initial Sample Date: 9/26/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Pomeroy Elementary School					
Initial Sample Date: 9/20/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Ponderosa Elementary School					
Initial Sample Date: 4/24/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Scott Lane Elementary School					
Initial Sample Date: 9/25/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	7.8	ND	ND	ND	ND
Resample Date: 10/11/2018	9.0				
Resample Date: 11/8/2018 Corrective Action Taken	ND				

**SANTA CLARA UNIFIED SCHOOL DISTRICT
LEAD TESTING OF DRINKING WATER RESULTS 2018**

ELEMENTARY SCHOOLS

Sutter Elementary School					
Initial Sample Date: 9/21/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	13.0	ND	ND	ND	ND
Resample Date: 10/11/2018	26.0				
Resample Date: 10/24/2018 Corrective Action Taken	ND				

Washington Open Elementary School					
Initial Sample Date: 9/25/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Westwood Elementary School					
Initial Sample Date: 9/21/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

K-8; MIDDLE SCHOOLS

Don Callejon (K-8) School					
Initial Sample Date: 9/26/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Buchser Middle School					
Initial Sample Date: 9/28/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Cabrillo Middle School					
Initial Sample Date: 9/19/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Peterson Middle School					
Initial Sample Date: 4/26/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

**SANTA CLARA UNIFIED SCHOOL DISTRICT
LEAD TESTING OF DRINKING WATER RESULTS 2018**

HIGH SCHOOLS

Santa Clara High School					
Initial Sample Date: 9/27/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Wilcox Clara High School					
Initial Sample Date: 9/28/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

New Valley/Gateway High School					
Initial Sample Date: 9/27/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Wilson High School / Education Options					
Initial Sample Date: 9/27/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Santa Clara Community Day School					
Initial Sample Date: 9/20/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3		
Results	ND	ND	ND		

**SANTA CLARA UNIFIED SCHOOL DISTRICT
LEAD TESTING OF DRINKING WATER RESULTS 2018**

ASSOCIATE & LEASED SCHOOL SITES

Martinson Child Development Center					
Initial Sample Date: 9/26/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Monticello Academy (Curtis Campus)					
Initial Sample Date: 10/3/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Monticello Academy Preschool (Monroe Campus)					
Initial Sample Date: 10/5/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Monticello School (Monroe Campus)					
Initial Sample Date: 10/5/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	6.5	ND	ND	ND
Resample Date: 12/4/2018 Corrective Action Taken		ND			

Patrick Henry Campus (Appleseed, Silicon Valley Academy, DRC)					
Initial Sample Date: 4/27/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Santa Clara Christian School (Monroe Campus)					
Initial Sample Date: 10/5/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND

Stratford School (Curtis Campus)					
Initial Sample Date: 10/3/2018 Sample areas: Exterior drinking fountains; classroom drinking fountains; kitchen sinks					
Sample Site	1	2	3	4	5
Results	ND	ND	ND	ND	ND